





Pipes are to be secured and not blowing in the wind. Pipes are to be attached to Unistrut with Unistrut straps. Not zip ties. Pipes are not to be secured with cloth to the racks.



Pipes are to be secured with roof mounts. Not tied with string or plastic. All pipes are to be repaired and secured.





Any disconnects with rusted holes in them are to be replaced. Pipes are not to be just left sitting on the roof.



Any abandoned disconnects or conduits are to be removed.



All disconnects are to be complete and not missing parts.



Basically, he wants all conduits secured and strapped. Any zip ties on the roof are to be sun resistant. Any and all abandoned equipment is to be removed.